



PAPAIOEA
PALMERSTON
NORTH
CITY

Approved Backflow Prevention Devices	
Approved Testable RPZ Devices	
For pipes >65mm in diameter approved devices are:	Wilkins Zurn 375 Series
For pipes 15mm to 50mm diameter approved devices are:	Watts 009 Series
	Apollo Series 4A-200
	Wilkins Zurn 375 Series
Approved Testable Double Check Valves	
For pipes >65mm in diameter approved devices are:	Wilkins Zurn 350 Series
For pipes 15mm to 50mm diameter approved devices are:	Watts 007 Series
	Apollo Series 4A-100
	Wilkins Zurn 350 Series

Note: Devices must meet the requirements of the codes and standards listed below;

- AS 2845:2010 Water Supply – Backflow Prevention - Part 1 Materials, Design and Performance Requirements
- NZ Building Code G12 Water Supplies
- G12/AS1 Acceptable Solutions