

COMPLIANCE SCHEDULE DETAILS:

SS 15/1 – SYSTEMS FOR COMMUNICATING SPOKEN INFORMATION TO FACILITATE EVACUATION

PLEASE PROVIDE THE FOLLOWING INFORMATION WITH YOUR BUILDING CONSENT APPLICATION - FORM 2

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Installation provider: (if known)
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Removed
Type:	A building intercom system for use by the Fire Service			
	A public address system to facilitate staged evacuation			
	An emergency warning intercommunications system (EWIS)			
	Other: [specify]			

Location plan for specified systems and records is attached: Yes No

No.	Equipment location	Make (main components)	Model
1			
2			
3			
4			
5			

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/ installation:	AS 2220:1989 Emergency warning and intercommunication systems in buildings Part 1: 1989 Equipment design and manufacture Part 2: 1989 System design, installation and commissioning	
	AS 2220.1-1989/Amdt 2-1993 Emergency warning and intercommunication systems in buildings	AS 1851-2012/Amdt 1-2016 Routine service of fire protection systems and equipment
	AS 1851-2012 Routine service of fire protection systems and equipment	AS 1851:2005 Maintenance of fire protection systems and equipment
	NZS 4512:2020 Fire detection and alarm systems in buildings.	NZS 4512:2010 Fire detection and alarm systems in buildings.

Continue on the next page

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/ installation:	<p>NZS 4512:2003 Fire detection and alarm systems in buildings.</p> <p>NZS 4512:1994 Fire alarm systems in buildings.</p> <p>NZS 4561:1973 Specification for manual fire alarm systems.</p> <p>Other:</p>	<p>NZS 4512:1997 Fire alarm systems in buildings.</p> <p>NZS 4512:1981 Automatic fire alarm systems in buildings.</p> <p>NZS 2211:1968 Manual fire alarm systems for use in buildings.</p> <p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</p>
Inspections:	<p>NZS 4512:2010 – Part 6</p> <p>NZS 4512:2003 – Part 6</p> <p>NZS 4512:1997 – Part 6</p> <p>NZS 4512:1994 – Part 6</p> <p>NZS 4512:1981 – Part 6</p> <p>Other: _____</p>	<p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).</p>
Maintenance:	<p>NZS 4512:2010 – Part 6</p> <p>NZS 4512:2003 – Part 6</p> <p>NZS 4512:1997 – Part 6</p> <p>NZS 4512:1994 – Part 6</p> <p>NZS 4512:1981 – Part 6</p> <p>Other:</p>	<p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).</p>

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	<p>Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, and to ensure the system will operate as required in the event of a fire.</p>
Inspection frequency and responsibility:	<p>Depending on the type of installation and its performance standard/document:</p> <p>Specifically designed solutions: by IQP only</p> <p>Standard /other document:</p> <p>Monthly: by IQP only</p> <p>Annually: by IQP only</p>