

COMPLIANCE SCHEDULE DETAILS: SS 1 – AUTOMATIC SYSTEMS FOR FIRE SUPPRESSION (E.G. SPRINKLER SYSTEM)

PLEASE PROVIDE THE FOLLOWING INFORMATION WITH YOUR BUILDING CONSENT APPLICATION - FORM 2

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Installation provider: (if known)
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Moved
Type:	Type 6 or	Type 7		
	Gas flood fire suppression system installed with a building for computer equipment protection.			
	Other: (specify)			

Location plan for specified systems and records is attached: Yes No

No.	Equipment location	Make (main components)	Model
1			
2			
3			
4			

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/ installation:	NZS 4541:2020 Automatic fire sprinkler systems.	NZS 4515:2009 Fire sprinkler systems for life safety in sleeping occupancies (up to 2000m ²)
	NZS 4541:2013 Automatic fire sprinkler systems.	NZS 4515:2003 Fire sprinkler systems for residential occupancies.
	NZS 4541:2007 Automatic fire sprinkler systems.	NZS 4515:1995 Fire sprinkler systems for residential occupancies (including private dwellings)
	NZS 4541:2003 Automatic fire sprinkler systems.	NZS 4515:1990 Residential fire sprinkler systems.
	NZS 4541:1996 Automatic fire sprinkler systems.	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).
	NZS 4541:1987 Automatic fire sprinkler systems.	
	NZS 4541P:1972 NZ rules for automatic fire sprinkler installations.	Other:

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Inspections:	<p>NZS 4541:2020 Part 12, Clause 12.3 to 12.4</p> <p>NZS 4515:2009 Part 8, Clause 8.2</p> <p>AS ISO 14520.1:2009 Part 9</p> <p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</p> <p>Other: _____</p>	<p>NZS 4541: 2013 Part 12, Clause 1203 to 1204</p> <p>AS 1851: 2012 Sections 1 to 14</p>
Maintenance:	<p>NZS 4541:2020 Part 12, Clause 12.1 to 12.7</p> <p>NZS 4515:2009 Part 8</p> <p>AS ISO 14520.1:2009 Part 9</p> <p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</p> <p>Other: _____</p>	<p>NZS 4541:2013 Part 12, Clause 1201 to 1207</p> <p>AS 1851:2012 Sections 1 to 14</p>

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	<p>Planned preventative inspection, maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure the system will operate as required in the event of a fire.</p>
Equipment requiring weekly maintenance:	<p>Building contains diesel fire pump</p> <p>Building contains an electric fire pump without an alarm</p>
Inspection & Maintenance - frequency and responsibility:	<p>Depending on the type of installation and its performance standard/document:</p> <p>Specifically designed solutions: by IQP only</p> <p>Standard /Standard /another document: _____</p> <p>Monthly: by IQP only</p> <p>Annually: by IQP only</p>
Inspections & Maintenance:	<p>Annual Inspection:</p> <p>The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually.</p> <p>The system is NOT connected to the building's emergency warning system.</p>
Reporting:	<p>The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:</p> <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. • Form 12A provided annually by the IQP.